



Telephone: 0484-2925765
email: qcsdlvypin@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, Vypin- 682508

WATER TEST-BACTERIOLOGY REPORT

Report No: VP/BC3099/11/24

Report Issue Date: 20.11.2024

Customer Name &Address MARELLO PUBLIC SCHOOL PERUMPILLY, NJARAKKAL	Date of Receipt of Payment	25.10.2024
	Date of Sample received	15.11.2024
	Sample given by	Customer
	Sample Code	VP/BC3099/11/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Tap Water
	Sample Quantity	200ml

Test performing dates : From: 19.11.2024 To :20.11.2024

Sl. No.	Source	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be detected/100ml	IS15185-2016	Absent
2	E Coli	Shall not be detected/100ml	IS15185-2016	Absent

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed & Authorized By

C.V. Sreelakshmi

KWA/QCSL/VP/F-21	Issue Date : 20.09.21	Issue no:01
Rev No: Nil	Rev Dt: Nil	Page 1 of 1
End of Report		

